

# Green Approach to Cooling Water Management

Innovative Polymers Pte Ltd (Singapore)

By: B.K Ng



# Agenda


1. Principles of Cooling Water Management
2. Innovation of DCI Technology
3. Successful Field Implementations and Performance
4. Site Installations
5. DCI Benefits

# 1. Principles of Cooling Water Management

Confidential

# Cooling Water Management

- ▶ Evaporation cools the recirculation water
- ▶ Evaporation increases the solid concentration
- ▶ Water and air borne bacteria causes Bio-fouling




# Problems Encountered



Scaling



Corrosion



Bacteria - Bio Fouling

- ▶ Scaling and Bio-Fouling impedes heat transfer in the chiller condenser tubes
- ▶ Due to inefficiency in heat transfer, chiller system consume more energy



Chiller System



# Cooling Water Treatment Methods (Conventional)

## ► Chemical Treatment

- Not Environmental Friendly
- Hazardous
- Tedious Control (Due to inconsistent load)


## ► Conductivity Control Blow Down

- Assumption control
- Water Wastage

## ► Physical Cleaning

- Costly
- Down Time

Confidential



## 2. Innovation of DeCalon™ (DCI) Technology

Confidential

# DCI Description & Objective

- ▶ DeCalon™ (DCI), is first of its' kind, patented revolutionary approach to eliminating scale, preventing corrosion and bio-fouling in cooling water systems
- ▶ The objective of DCI is to save energy, water and chemicals in cooling water management
- ▶ Changing the way we treat water!





## DeCalon System

- ▶ Invented in Singapore
- ▶ Patented Technology
- ▶ Started in 2014
- ▶ More Than 120 Installations World Wide




# Innovation of the DCI Technology

Through **Electrochemistry**, **CataGreen™** anti-bio technology and **Software control**:

►DCI dissolves the existing scales from the pipe, cooling tower and heat exchanger and prevents further scale formation due to evaporation continuously.

►DCI prevents corrosion by removing the Dissolved Oxygen (lowers ORP) and creates an alkaline environment. (pH Control)

DCI's proprietary non-chemical CataGreen™ disinfects water to prevent bio-fouling, algae, heterotrophic and Legionella bacteria.




# CataGreen™



- ▶ A proprietary non chemical device to enhance the DCI's performance
- ▶ It also disinfects the Heterotrophic and Legionella bacteria to <100,000 and <10 cfu/ml respectively.
- ▶ DCI + CataGreen = Chemical Free Approach for Cooling Water Management

Diagrams (by Gamma Ray) indicate tube blockage and followed by reduction after 2 months of exposure to the Electrolytic Descaling Process



# Comparison

Functionality	DeCalon (DCI)	Chemical Treatment	Ball Technique System	Auto Brush System
Ability to Clean the Entire Cooling Circuitry (Condenser Loop)	✓	Prevention Only	X	X
Removal of Existing Hard Scales	✓	X	X	X
Corrosion Prevention	✓	✓	X	X
Treatment Approach	Prevent & Cure	Prevention	Cure	Cure
Ease of Operation and Maintenance	✓	X	X	X
Periodical Washing & Chemical Cleaning	Reduced	Frequent	Frequent	Frequent
Clean and Green Technology	✓	X	X	X





### 3. Successful Field Implementation and Performance





Confidential



# Performance Indicator

- ▶ Chiller Efficiency (kW/Ton)
- ▶ Condenser Approach Temp.
- ▶ kW usage (Power Consumption)
- ▶ C.T Blow Down Water




# DCI in Keppel Bay Tower, Singapore



**Toward Super Low Energy Building (SLEB) Status**

# Chiller Performance @Keppel Bay Tower



Data Analytics by IPMVP Standards

## KBT's Main Findings

Based on International Performance Measurement & Verification Protocol (IPMVP Vol 1),

KBT's Chiller Plant Performance (different from Chiller Performance) in Nov-18, Jan-19 & Feb-20 @ 784RT (70% load) is as follows:

- |                                       |                                     |
|---------------------------------------|-------------------------------------|
| ▶ Nov-18 (Baseline-No DCI) @ 70% load | ▶ 0.619 kW/RT (Baseline)            |
| ▶ Jan-19 @ 70% load after 2 months    | ▶ 0.584 kW/RT, Power Saving = 5.65% |
| ▶ Feb-20 @ 70% load after 14 months   | ▶ 0.575 kW/RT, Power Saving = 7.10% |



# Bacteria Control @Keppel Bay Tower Singapore

## Keppel Bay Tower

Cooling Tower	CT1		CT2		CT3		CT4		CT4A	
Bacteria	HB	LB	HB	LB	HB	LB	HB	LB	HB	LB
1/11/2018,baseline	2900									
Dec-18	170	ND								
Jan-19	68	ND	83	ND	63	ND	16	ND	6	ND
Feb-19	330	ND	200	ND	190	ND	450	ND	220	ND
Mar-19	810	NT	3400	NT	770	NT	1900	NT	340	NT
Apr-19	110	NT	280	NT	250	NT	400	NT	170	NT
May-19	310	ND	340	ND	320	ND	38	ND	17	ND
Jun-19	130	ND	130	ND	110	ND	1400	ND	870	ND

**HB** = Heterotrophic Bacteria Count,  
**LB** = Legionella Bacteria Count

Control limit < 100,000 CFU/ml  
 Control limit < 10 CFU/ml

**ND** = Not Detectable

**NT** = Not Tested

## Corrosion Control @Keppel Bay Tower Singapore

Date Started : 18 Jan 2019

Date Completed : 18 Jul 2019

Test Duration : 6 months

Test Report : By an accredited lab



CDA122 Copper



C1010 Mild Steel

Coupon Metallurgy	Coupon Part No.	Serial No.	Weight New (gram)	Weight After (gram)	Weight Difference (gram)
C1010 Mild Steel	CO1733750104100	121	9.7553	9.5765	0.1788
CDA122 Copper	CO17342101104100	011	11.0287	11.0230	0.0057

Mild steel corrosion rate = 1.18 MPY

Copper corrosion rate = 0.03 MPY

Std ind mild steel spec < 3.0 MPY

Std ind copper spec < 1.0 MPY

MPY = Mil Per Year



# 3M Singapore 2019

## Industry

Production Factory

## Chiller Capacity

2000RT

## Cooling Purpose


Air Conditioning

## Key Performance

- 5% Energy savings
- 50% Blow down water saved
- Zero chemical discharge



# 3M Singapore 2019



## Chiller Tube Scope

Chiller 1 - Chiller Tubes after 10 months operating with DCI system

# Malaysia, Johor F&B Factory - 2015

## PROCESS COOLING

### Industry

Food and Beverages

### Cooling Tower Capacity

100RT

### Chiller Capacity


80RT

### Cooling Purpose

Chilled water is supplied to production machines for process cooling

### Key Performance

- Estimated energy savings : 77,760 kWh/year
- Percent Power Savings : 16.9%
- Water Savings : 88%
- Production Process Improved



# Barry Callebaut Malaysia 2017

Condenser Approach Temp. @ Barry Callebaut Malaysia Chiller 5



## Industry

Food and Beverages

## Cooling Tower Capacity

500RT

## Chiller Capacity

300RT

## Cooling Purpose

Chilled water is supplied to production machines for process cooling

## Key Performance

Estimated energy savings : 150,000 kWh/year

Percent Power Savings : 15.2%

Water Savings : 50%

Chemical Savings : 100%



# Philippines, Semi-Conductor Factory -2016

## HVAC System


Industry  
Semi Conductor

Cooling Tower Capacity  
5000RT

Chiller Capacity  
2000RT

Cooling Purpose  
Air Conditioning

Key Performance  
Estimated energy savings : 740,260 kWh/year  
Percent Power Savings : 11.2%  
Water Savings : 27%  
Chemical Savings : 100%



Confidential



## Singapore, SIMTech A\*Star Research Lab - 2015

### HVAC System

#### Industry

Research Laboratory

#### Cooling Tower Capacity

250RT

#### Chiller Capacity

164RT



#### Cooling Purpose


Chilled water is supplied to AHU for clean room air conditioning

#### Key Performance


- Estimated energy savings : 80,680kWh/year
- Percent Power Savings : 17.5%




# Singapore, SIMTech A\*Star - 2015



# Singapore, SIMTech A\*Star - 2015



Average temp difference from set point = 0.04 °C



Average RH difference from set point = 4.84%

# New Zealand, Hospital - 2015

## HVAC System

**Industry**  
Hospital


**Cooling Tower Capacity**  
200RT

**Chiller Capacity**  
160RT

**Cooling Purpose**  
Air Conditioning

### **Key Performance**

Percent Power Savings : 17%  
Water Savings : 41%  
Chemical Savings : 100%



Confidential



# Other Sites



# Our Customers



## Our Distribution Network

Singapore (HQ)

Malaysia

Thailand

Indonesia

Europe

USA

New Zealand

Australia

India

Vietnam

Taiwan





# Our Credentials



## 4. Site Installation

Confidential


## Single DCI (Average 350 to 400RT Chiller Capacity)



## Multiple DCIs



# DCI System Flow Schematic



- ❑ Stand alone system
- ❑ No shut down required during installation
- ❑ Does not interfere with clients' system
- ❑ Conductivity control blow-down no longer required (water saving)

## 5. DCI Benefits

Confidential



## DCI Benefits

- ▶ **Energy savings between 5% to 25%**

Optimal performance of water-cooled chillers at all time

- ▶ **Water savings > 50%**

Cycle of concentration (COC) will increase due to Minimal Blow-Down

- ▶ **Chemical savings 100%**

No hazardous chemicals required

- ▶ **Higher Product Yield & Improved quality**

More efficient cooling

- ▶ **Increases Productivity**

Reduced downtime

# Excellent Technology



- ❑ Reduction in CO<sub>2</sub> Emission/  
Footprint
- ❑ True CLEAN AND GREEN

Confidential

# Our Questionnaire

## DeCalon Questionnaire for Aircon Application

Date:  Confidential Company:

**1 Chiller operating hours**  
Chiller operating days  h/d  
 d/year

### 2 Chiller/Cooling system configuration

Unit capacity on duty  
Quantity on duty in parallel  
Standby quantity  
% average operating load

W/CPU	Chiller	C.Tower	
			RT/unit
			Units
			Units
			%

### 3 Chiller data


Chiller efficiency @ 100% load

Now	When New	
		kw/RT

Chiller Age  Years

Chiller type (1= Centrifugal,2=Helical/Screw,3=Reciprocating,4=others)  Centrifugal

### 4 Temperature data @ above % chiller operating load



		Now	New
	Location	Temp °C	Temp °C
T1	C.Tower -in		
T2	C.Tower -out		
T3	Condenser-in		
T4	Condenser-out		
T5	Sat Rfgrt -out		

°C = (F-32) x 5/9  
CAT = Condenser Approach Temp

CAT	Now	When New
T5-T4		

### 5 Cooling Tower

Cooling Tower water flowrate (recirculation)  
Cycle Of Concentration (COC)  
Cooling Water blow-down  
Cooling tower make-up

US gpm ÷ 4.4 = m<sup>3</sup>/h

<input type="text"/>	m <sup>3</sup> /h
<input type="text"/>	Cycles
<input type="text"/>	m <sup>3</sup> /mth
<input type="text"/>	m <sup>3</sup> /h

### 6 Water analysis (ppm as CaCO<sub>3</sub> where applicable)

pH  
Ca<sup>2+</sup>  
Mg<sup>2+</sup>  
Cl  
T.Alkalinity  
SO<sub>4</sub><sup>2-</sup>  
SiO<sub>2</sub> as SiO<sub>2</sub>  
Conductivity,uS/cm

Make up H <sub>2</sub> O	Cooling H <sub>2</sub> O

### 7 Present treatment chemicals used (if any)

State currency  Local currency / mth

### 8 Heat exchanger/condenser tube yearly cleaning + maintenance cost

Local currency / year

### 9 Electricity cost (average)

Local currency/kWh

### 10 Water cost

Local currency/m<sup>3</sup>

### 11 Chiller/Cooling Tower and configuration flow schematic

Pse attach a sketch with this Questionnaire

# Q&A

Confidential

***Thank You!***

B.K Ng

[Bk.ng@innovativepolymers.com](mailto:Bk.ng@innovativepolymers.com)

[www.decaion.com.sg](http://www.decaion.com.sg)